

FERMIN MARTINEZ P.E.  
7590 S.W. 82 Street #120  
Miami, Florida  
Tel. 305 298-3216

AS BUILT CERTIFICATE

November 23, 2011

Metropolitan Dade County  
Building & Zoning Department  
11805 SW 26 Street  
Miami, Florida 33175

Owner: Marlene I. Campbell  
Address: 16000 SW 100 ct  
Miami, Florida 33157

Structures to be legalized:  
(A)Garage Enclosure

Dear Sirs:

I hereby attest that, the structure is structurally sound and the work satisfies the requirements of the Code in effect.

My statement is based on the following detailed, methodology produce:

The reinforcing re-bars were detected and supplemental accuracy was obtained by means of visual response and using the Profometer 5 Rebar and metal probe locator from "PROCEQ".

Garage door to remain and enclosed with wood framing partition.

WOOD FRAMING: Verified 2" x 4" PT plate with 5/8" x 6" anchor bolts @ 24 stg. Wood bracing 2" x 4" and 2"x 4" studs @ 16" o.c.

INSULATION: Verified interior wall has been insulated with R5 and roof with R-30 and partition R 13

DRYWALL: Verified that 1"x 2" pt.furr. Strips @ 24 o.c. with 1/2" gyp.bd. structure also complies with all requirements of the Florida Building Code,

Miami Dade County Building Department

0000709054 - 1/5/2012 8:17:20 AM

GENERAL01-11302011.pdf

Examiner Date Examined

Mario Soto 12/2/2011 11:28:30 AM D BLDG Disapproved

The structure also complies with all requirements of the Florida Building Code, Section 301.5(k). with the permit application and any plans approved by the Building Official, if applicable.

*Fermin G. Martinez 11/23/11*  
FERMIN MARTINEZ P.E.  
License #19363

Miami Dade County Building Department

0000709054 - 1/5/2012 8:13:20 AM

GENERAL01-11302011.pdf

<u>Examiner</u>	<u>Date Time Stamp</u>	<u>Disp.</u>	<u>Trade</u>	<u>Stamp Name</u>
Mario Soto	12/2/2011 11:26:50 AM	D	BLDG	Disapproved